

WELL COMPLETION REPORT

3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1058

OWNER	NAME EDWARD VARLEY		ADDRESS LAGUNA ROAD, LAKE CARMEL, NEW YORK	
LOCATION OF WELL	(No. & Street) (Town) (Lot Number) LAGUNA ROAD, LAKE CARMEL, NEW YORK			
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 20 ft	DIAMETER (inches) six	WEIGHT PER FOOT 19 lb.	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS five G.P.M. five YIELD (G.P.M.) five (5)
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 28 feet		DURING YIELD TEST (feet) <u> </u>	
SCREEN DETAILS	MAKE		Depth of Completed Well in feet below Land surface: 160 ft.	
	SLOT SIZE		LENGTH OPEN TO AQUIFER (feet)	
	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)
DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION		Sketch exact location of well with distances, to at least two permanent landmarks.
0	3	Drilling in overburden - earth		
		Hit solid rock at 3 ft.		
3	20	Drilling in rock - setting casing - grouted		
20	160	Drilling in rock - granite		
If yield was tested at different depths during drilling, list below				
FEET		GALLONS PER MINUTE		

DATE WELL COMPLETED

7/26/72

DATE OF REPORT

12/14/72

WELL DRILLER (Signature)

P. F. BEAL & SONS, INC.

Malcolm F. Beal Jr.